

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


No. 05

Dated: 27-04-2024

It is certified that an inspection team headed by SANTOSH KUMAR, EXECUTIVE ENGINEER (Name of Officers with designation) from UP JAL NIGAM, SULTANPUR (Name of Department/ Office) inspected the RAGHUKUL ACADEMY ENGLISH MEDIUM SCHOOL, LAMBHUA, SULTANPUR (Name & Address of the school) on 26-04-2024 (date of inspection), and on the basis of Water Test report (attached) bearing no. 169/24-25 | Dated: 28.04.2024 of District Water Testing Lab, Divisional Office, UP Jal Nigam (Rural) Sultanpur (PHED LAB) certified that the RAGHUKUL ACADEMY ENGLISH MEDIUM SCHOOL has safe drinking water facilities for the students and member of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

The certificate is valid till ONE YEAR i.e. 27.04.2025.

Signature with Seal:

  
23/4/24

Name: SANTOSH KUMAR

Designation: EXECUTIVE ENGINEER

Executive Engineer  
Assistant Engineer of Division  
the Govt. Public Health Department  
(PHED)/ Sultanpur

Authorised officer of the Local Body  
Name & Address of the Office /

Department: UP JAL NIGAM (RURAL),  
SULTANPUR

To,

RAGHUKUL ACADEMY ENGLISH MEDIUM SCHOOL

LAMBHUA, SULTANPUR

Principal  
Raghukul Academy  
English Medium School,  
Lambhua, Sultanpur

राम लीच सिंह  
Manager  
Raghukul Academy English  
Medium School, Lambhua, Sultanpur



# Analysis Report



District Level Water Analysis Laboratory, U.P. Jal Nigam  
(Rural), Sultanpur

Certificate No.: TC-12204

Rept No.	Chemical Test169/2024-2025	Date	26-04-2024	Page.No.	1	Page 1/1
----------	----------------------------	------	------------	----------	---	----------

### Customer Details

Office Name and Address	RAGHUKUL ACADEMY ( ENGLISH MEDIUM SCHOOL ), Garyen Road, Lambhua-Sultanpur					
Ref Letter No & Date	Date 25-04-2024					

### Basic details of sample

District	Sultanpur	Block	Lambhua
Gram Panchayat	Lambhua Bazar	Village	
Habitation		Location	
Water Source	R.O. Water	Sample No.	169
Quantity of Sample	1000 ml	Date of Sample Collection	25-04-2024
Receiving Date:	25-04-2024	Sample Collector	By the Customer: Ram Tirath
Sample Depositer	By the customer: Ram Tirath		
Analysis Start Date	26-04-2024	Analysis Completion Date	26-04-2024

### Environmental Condition

Temperature	25±3 oC	Humidity	50±15%
-------------	---------	----------	--------

### Technical Data of Analysis

S No.	Parameter	Units	Observed Value	Specified Values as per		Ref. Method of Analysis
				Acceptable limit	Permissible Limit	
1	2	3	4	5	6	7
1	Turbidity	(NTU)	3.6	1.00	5.00	IS 3025 (Part 10) : 2023
2	pH Value		7.38	6.5-8.5	6.5-8.6	IS 3025 (Part 11) : 2012 (RA :2022)
3	TDS	(mg/L)	430	500.00	2000	IS 3025 (Part 16) : 2023
4	Fluoride	(mg/L)	0.225	1.00	1.5	IS 3025 (Part 60) : 2008 ( Electro. Chem. Prob Meth)
5	Chloride	(mg/L)	39.9876	250.00	1000	IS 3025 (Part 32) : 2014 (RA: 2019)
6	Iron	(mg/L)	0.38	0.30	1	APHA 23rd Edition-3500-Fe Method B(Phenanthroline)
7	Sulphate	(mg/L)	11.95	200.00	400	IS 3025 (Part 24) : 2009 (RA: 2022)
8	Nitrate	(mg/L)	14.48	45.00	45	APHA 24rd Edition 2023, Meth, 4500 NO <sub>3</sub> -B
9	T. Alkalinity	(mg/L)	300	200.00	600	IS 3025 (Part 23) : 2023
10	T. Hardness	(mg/L)	340	200.00	600	IS 3025 (Part 21) : 2009 ( RA: 2023)
11	Calcium	(mg/L)	32.064	75.00	200	IS 3025 (Part 40) : 2019
12	Magnesium	(mg/L)	63.18	30.00	100	IS 3025 (Part 46) : 2019
13	Taste	Qualitative	Agreeable	-	-	IS 3025 (Part 08) : 2023
14	Odour	Qualitative	Agreeable	-	-	IS 3025 (Part 05) : 2018
15	Colour	Hazen	5	5	15	IS 3025 (Part 04) : 2021

- Note:
1. This Certificate refers only to the particular sample(s) submitted for testing.
  2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head Of Laboratory.
  3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
  4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

*RK*  
(Rukumkesh verama)  
Lab Technician  
Prepared By

Authorized Signatory  
*Ram Badan Yadav*  
Technical Manager  
Ram Badan Yadav  
District Level Water Analysis Laboratory  
Sultanpur UP, IN

\*\* End of Test Report\*\*

Contact details - Email-upjnsl44lab@gmail.com Mob- 8382822001

Principal  
Raghukul Academy  
English Medium School  
Lambhua Sultanpur

21/04/2024  
Manager  
Raghukul Academy English  
Medium School, Lambhua Sultanpur